

THICKNESS OF GROUT TO BE APPROXIMATELY ONE HALF INCH (1/2"). CONTINUE SLOPE OF PIPE THROUGH MANHOLE, 2% MINIMUM SLOPE.

3. WHEN FOUR (4) LINES COME INTO A MANHOLE, THE TWO LINES WHICH EMPTY INTO THE MAIN CHANNEL ARE TO BE STAGGERED AND NOT SET SO THEY WILL EMPTY IN AT THE SAME POINT.

4.ALL CONCRETE TO BE SIX (6) SACK.

STANDARD DETAIL MANHC PRECAST DATE:5/3/2004 APPROVED. BY: DAVE (ROSS DATE:5/3/2004 DATE:5/3/2004 CK. BY: DR. BY: